



1500 Brigantine Drive
Coquitlam, BC, V3K 7C1

Telephone: 604-520-3321
Facsimile: 604-524-9186
www.intertek.com

July 14, 2014

Project No. G101733656

Peter Anglin
V.P. Tile Imports Ltd.
7073 Kingswood Court
Delta, BC V4E 2S3
Canada

Ph: 604-594-9902
Fx: 604-594-5766
email: vptileimports@dccnet.com

Subject: Findings Letter Report 101733656COQ-001

Dear Mr. Anglin,


Intertek has conducted slip resistance testing on your tile product in accordance with Section 9.6 *Procedure for Dynamic Coefficient of Friction (DCOF) Testing of ANSI A137.1-2012, American National Standard Specifications for Ceramic Tile*. The tile samples were submitted to the Evaluation Center on July 2, 2014 and were identified as Coquitlam ID# VAN1407140919-001. Testing was conducted in the wet condition using a BOT 3000 (Intertek ID# P60695, cal due June 17, 2015) with a 0.05% sodium-lauryl sulphate (SLS) water solution. Four (4) dynamic measurements were taken on each tile and then averaged; a total of three (3) tiles were tested. Testing has been completed and results of the testing can be found below:

Table 1. Test Results			
Description	Result	Requirement	Pass/Fail
TopCer Industries Ceramics – Porcelain – Size: 96 x 96 x 8mm – Unglazed Smooth – Colour: 4401	0.62	≥ 0.42	Pass

If there are any questions regarding the results contained in this report, or any of the other services offered by Intertek, please do not hesitate to contact the undersigned.


Completed by: Geri Nishio
Senior Technician,
Building Products

Title:
Signature:



Reviewed by: Baldeep Sandhu
Lab Supervisor,
Building Products

Title:
Signature



This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only the sample tested. This report by itself does not imply that the material, product or service is or has ever been under an Intertek certification program.

